



CITY OF HOUSTON

Fire Department

E. A. Corral

Fire Marshal

Fire Prevention Division
2931 W. 12th Street
Houston, Texas 77008

T.713.865-7100
F.713.865-7193

Subject: Open-flame *Sterno*-type product use

The use open-flame devices such as *Sterno* and all similar products in assembly occupancies for heating of foods and/or beverages will be permitted in accordance with the City of Houston *Fire Code*, Section 308.5, provided the following procedures and safety precautions are met:

- a. *Sterno* containers must be used in holder devices designed and manufactured for that purpose. *Sterno* containers not in an approved holder shall be not be allowed.
- b. Materials used on the table must be flame retardant. Any and all materials used to shield the heating devices from sight shall be flame retardant and kept clear of any contact with the open-flame containers. The shielding materials shall not interfere with ready access to the containers.
- c. At least one 2A-10BC fire extinguisher must be readily accessible within 25 feet. In addition, dampened towels should be provided in the immediate vicinity.
- d. Persons responsible for setting up and maintaining the *Sterno* must be trained in maintaining the approved table layout and in the use of a fire extinguisher.
- e. The set up must not be left in an unoccupied area. The person responsible for setting up and maintaining the table where *Sterno* is used for warming food or beverages (small scale serving) may leave the room temporarily provided the other occupants are aware of the open flame (small signs must be posted for said warnings).
- f. Storage of *Sterno* and all similar product containers shall be in an accordance with the *Fire Code* as to appropriate storage requirements per building and occupancy type, and the amount being stored.

